



Brent Adamson
Duquette Pines HOA
PO Box 252
Idaho City, ID 83631

CERTIFICATE OF ANALYSIS

Client:	Duquette Pines HOA		
Lab ID:	E170200109-001 (190402)	Collected:	02/17/2017 09:15
Sample ID:	#2	Received:	02/17/2017 11:39
Location:	Duquette Pines HOA	Reported:	02/25/2017 01:46
		Matrix:	Drinking Water

Additional Information / Comments

Sample Type Code: Routine Sample

-- Microbiological --

Parameter	Result	Analyzed	By	Qual
<i>Analysis Desc: SM 8223B-PA-CT</i>				
Total Coliform	Absent	02/17/2017 15:55	RE	
<i>E. coli</i>	Absent	02/17/2017 15:55	RE	



Workorder: E160600025 060316

ANALYTICAL RESULTS

Chemistry samples are disposed of after 60 days unless the laboratory is notified otherwise.

Lab ID: E160600025-002 Date Received: 6/3/2016 10:44 Matrix: Drinking Water (Potable)
Sample ID: Tag # E0006271M Date Collected: 6/3/2016 07:15
Location: Manifold Wells 2,3,5

-- Metals --

Parameters	Results	Units	Detection Limit	Analyzed	By	Qual	MCL
Preparation Method: EPA 200.8							
Analytical Method: EPA 200.8							
Arsenic	0.0076	mg/L	0.0020	6/7/2016	HH		

-- General Chemistry --

Parameters	Results	Units	Detection Limit	Analyzed	By	Qual	MCL
Preparation Method: EPA 300.0							
Analytical Method: EPA 300.0							
Nitrate as N	1.36	mg/L	0.18	6/3/2016	VW		10

CERTIFICATE OF ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Idaho Bureau of Laboratories. Idaho Bureau of Laboratories retains all records for a minimum of five years.



Workorder: E160600025 060316

ANALYTICAL RESULTS

Chemistry samples are disposed of after 60 days unless the laboratory is notified otherwise.

Lab ID: E160600025-001 Date Received: 6/3/2016 10:44 Matrix: Drinking Water (Potable)
Sample ID: Well #1 Tag # E0006278 Date Collected: 6/3/2016 07:30
Location: Duquette Pines

-- General Chemistry --

Parameters	Results	Units	Detection Limit	Analyzed	By	Qual	MCL
Preparation Method: EPA 300.0							
Analytical Method: EPA 300.0							
Nitrate as N	1.36	mg/L	0.18	6/3/2016	VW		10

CERTIFICATE OF ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Idaho Bureau of Laboratories.
Idaho Bureau of Laboratories retains all records for a minimum of five years.